

**Chen, Isaac**

---

**From:** Saladen, Michael Thomas <saladen@lanl.gov>  
**Sent:** Monday, September 15, 2014 11:10 AM  
**To:** Chen, Isaac  
**Cc:** Saladen, Michael Thomas; Bailey, Marc A  
**Subject:** New Npdes Permit Comments

Isaac,

Another comment regarding the new NPDES permit (see paragraph below). The letter sent last week included comments and requests for clarification regarding the new permit requirements to be part of the administrative record. Please include the comment below. Thanks!!!

Mike

**NPDES Outfall 13S:**

Outfall 13S is located at the TA-46 Sanitary Waste Water System (SWWS) Plant and potentially discharges treated sanitary wastewater effluent to the TA-3-336 Reuse Tank for tertiary treatment at the TA-3 Sanitary Effluent Reclamation Facility (SERF) or directly to NPDES Outfall 001; or directly into Canada Del Buey. The SWWS Plant has never discharged to Canada Del Buey since beginning operations in 1992. The permittee will properly operate and maintain these facilities pursuant to Part III. B and will not discharge to Canada del Buey unless under emergency conditions. If a discharge occurs to Canada del Buey, the permittee will notify EPA pursuant to Part III.D. of the Laboratory's NPDES Permit.